



## WEST JORDAN FIRE DEPARTMENT - Pre-Fire Inspection Checklist

7602 S. Jordan Landing Blvd, West Jordan, UT. 84084

Office (801) 260-7300 Fax (801) 260-7321

### ADDRESS

Property address posted on street side of the building (6" tall)	IFC2009 505.1
--	---------------

### ELECTRICAL

All outlets, switches, and electrical boxes are properly covered	IFC2009 605.6
Electrical panels properly covered and latched	IFC2009 605.6
Electrical panels are accessible (min. 30" width, 78" height, 36" in depth)	IFC2009 605.3
Extension cords are for temporary use only, not through walls, ceilings, under doors or floor coverings	IFC2009 605.5
Electrical multi-plug adapters: approved internal circuit breaker-type only, must be UL-listed and plugged directly into outlet, cannot "piggy-back" EMP adapters	IFC2009 605.4.1

### EXITS

Exit doors unlocked during business hours	IFC2009 1008.1.9.3
Exit ways from obstructions	IFC2009 1015.2
Exit signs were required	IFC2009 1011.1
Lighted exit signs operating properly	IFC200 1011.2
No storage under unprotected exit stairways	IFC2009 315.2.4

### EXTINGUISHERS

Minimum size: 2A:10BC (5 lbs.) extinguisher	IFC2009 906.2
Extinguisher has a current State Fire Marshal inspection tag	IFC2009 901.6.1
Properly mounted and accessible (no more than 5', no less than 4" from floor)	IFC2009 906.9
Correct number and type for occupancy	IFC2009 906.3
Dry chemical suppression systems (paint & spray booths, etc.) inspected every 6 months	IFC2009 904.6
Wet chemical suppression systems (kitchen hoods, etc.) inspected every 6 months	IFC2009 904.5

### HOUSEKEEPING

Dispose of combustible waste (boxes, papers, debris, etc.)	IFC2009 304.1
Exterior free of trash and weeds	IFC2009 304.1.1
Oily rags stored in approved containers	IFC2009 304.3.1
All ceiling tiles in place and intact (no holes)	IFC2009 703.1

### MECHANICAL

No combustibles stored in furnace, boiler, electrical, or sprinkler riser room	IFC2009 315.2.3
Furnace, boiler, water heater, etc., vented to prevent a fire hazard	IFC2009 603.5
Gas meter protected and accessible	IFC2009 603.9

### SMOKING

Prohibited in warehouse storage areas and/or other hazardous areas	IFC2009 310.1
--	---------------

### STORAGE

All flammable and combustible liquids are stored properly	IFC2009 3404.3
Accumulated flammable and combustible liquids do not exceed allowable quantities	IFC2009 3405.3.5.2
Compressed gas cylinders secured from falling	IFC2009 3003.5.3
No combustible storage in unprotected attics or crawl spaces	IFC2009 315.2.4
Storage maintained 24" below ceiling (non-sprinklered building), 18" below (sprinklered building)	IFC2009 315.2.1

### ALARM AND SPRINKLER SYSTEMS (if applicable)

Fire and life safety systems are maintained in an operable condition	IFC2009 907.9
Sprinkler riser room and fire alarm panel readily accessible	IFC2009 509.2
Sprinkler system inspected and tagged annually	IFC2009 901.6.1