



## **WEST JORDAN FIRE DEPARTMENT Pre-Fire Inspection Checklist**

7602 S. Jordan Landing Blvd., West Jordan, UT. 84084

Office (801) 260-7300 Fax (801) 260-7321

### **ADDRESS**

Property address posted on street side of the building (4" minimum height)	IFC2012 505.1
--	---------------

### **ELECTRICAL**

All outlets, switches, and electrical boxes are properly covered	IFC2012 605.6
Electrical panels properly covered and latched. No open wire splices.	IFC2012 605.6
Electrical panels are accessible (min. 30" width, 78" height, 36" in depth)	IFC2012 605.3
Extension cords are for temporary use only, not through walls, ceilings, or under doors	IFC2012 605.5
Electrical multi-plug adapters: approved internal circuit breaker type only and plugged directly into outlet, cannot "piggy-back" EMP adapters	IFC2012 605.4

### **EXITS**

Exit doors unlocked during business hours	IFC2012 1008.1.9.3
Exits shall be unobstructed at all times	IFC2012 1015.2
Exit signs where required	IFC2012 1011
Lighted exit signs operating properly	IFC2012 1011.6.3
No storage under unprotected exit stairways	IFC2012 315.3.4

### **EXTINGUISHERS**

Minimum size: 2A:10BC (5 lbs.) extinguisher	IFC2012 906.3
Extinguisher has a current State Fire Marshal inspection tag	IFC2012 901.6.1
Properly mounted and accessible (no more than 5', no less than 4" from floor)	IFC2012 906.9
Correct number and type for occupancy	IFC2012 906.3
Dry chemical suppression systems (paint & spray booths, etc.) inspected every 6 months	IFC2012 904.6
Wet chemical suppression systems (kitchen hoods, etc.) inspected every 6 months	IFC2012 904.5

### **HOUSEKEEPING**

Dispose of combustible waste (boxes, papers, debris, etc.)	IFC2012 304.1
Exterior free of weeds	IFC2012 304.1.2
Oily rags stored in approved containers and removed and discarded daily	IFC2012 304.3.1
All ceiling tiles in place and intact (no holes)	IFC2012 703.1

### **MECHANICAL**

No combustibles stored in furnace, boiler, or sprinkler riser room	IFC2012 315.3.3
Furnace, boiler, water heater, etc., vented to prevent a fire hazard	IFC2012 603.3
Gas meter protected and accessible	IFC2012 603.9

### **SMOKING**

Smoking of any type prohibited in warehouse storage areas and/or other hazardous areas	IFC2012 310.1
--	---------------

### **STORAGE**

All flammable and combustible liquids are stored properly	IFC2012 5704
Accumulated flammable and combustible liquids do not exceed allowable quantities	IFC2012 5704.3.4
Compressed gas cylinders secured from falling	IFC2012 5303.5
No combustible storage in unprotected attics or crawl spaces	IFC2012 315.3.4
Storage maintained 24" below ceiling (non-sprinklered building), 18" below (sprinklered building)	IFC2012 315.3.1

### **ALARM AND SPRINKLER SYSTEMS (if applicable)**

Fire and life safety systems are maintained in an operable condition at all times	IFC2012 901.6
Sprinkler riser room and fire alarm panel readily accessible	IFC2012 509.2
Alarm systems and fire sprinkler systems shall be inspected and tagged annually	IFC2012 901.6